

**The following provisions are additions and modifications to Part II of General Legislation of the Town of Cortlandville Code, Part 1, Article 1, Chapter 171 - Water and Sewers.**

---

**A. Add 3 subsections (E, F and G) to §171-2; Applications and Permits**

1. All water project plans need to be reviewed and /approved by the Cortland County Health Department before any type of installation of any water project can be started.
2. All water project plans must to be reviewed and approved by the Water/Sewer Superintendent or his designee prior to any installation work.
3. No permit will be issued to any person or persons who are indebted to the Town of Cortlandville.

**B. Add a subsection (A)(3) to §171-4; Services**

- Any copper service line up to 1” in diameter and is over 200’ in length or any plastic service line with a connection between the Curb stop and the first shut off, requires a meter pit at the right of way or at a location approved by the Department head or his designee. Any service line greater than 1” shall be 4” D.I. pipe (Refer to section 171-13 B.C and D for installation and testing procedure.

**C. Add a subsection 4(E)(5) to §171-4; Services**

- Only one connection shall be allowed between the curb box and the first shutoff inside the building and there shall be no connections between the corporation and the curb box

**D. Add a subsection 4(E)(6) to §171-4; Services**

- There shall be no sweat fittings before the first valve within any building.

**E. Add a subsection I to §171-6; Meters**

- Any customer wishing to dispute the accuracy of a meter shall complete a customer Dispute Form and file the same with the Town within 30 days from the billing date in question.

**F. Delete subsections (6)(H)(1) and (6)(H)(1) of §171-6; Meters**

- these provisions allow for a second meter

**G. Replace subsections (6)(H)(1) and (6)(H)(2) of §171-6; Meters with new subsection 1**

- All bypass lines installed in the Town shall have a meter and a backflow device installed in that line.

**H. Change subsection A of §171-10; Bills and Payments**

- Change payable at the “office of the Town Department of Water and Sewer” to “Office of the Town Clerk.”

**I. Change subsection D of §171-10; Bills and Payments**

- Change “Town Department of Water and Sewer” to “Office of the Town Clerk.”

**J. Change subsection D of §171-10; Bills and Payments**

- Change “turned off by an employee of the Town Board” to “turned off by an Town Water/Sewer Department Operator or employee thereof.”

**K. Change subsection E of §171-10; Bills and Payments**

- Change “making application at the office of the Town Water Department” to “making application at the office of the Town Clerk.”

**L. Add subsection F of §171-12; Hydrants and Valves**

- Any fire hydrant outside the Town’s right of way is considered private and therefore shall be the responsibility of the property owner to test and maintain.

**M. Add a sentence to subsection E of §171-14; Technical standards and specifications for connecting water systems and mains**

- All installed brass fittings that come in contact with potable water shall not be composed of lead

**N. Add subsection I of §171-14; Technical standards and specifications for connecting water systems and mains**

- All water mains, fitting, valves and fire hydrants shall have a minimum cover of 5 feet but not less than 6 inches in diameter.